


調査結果表（歩道部B）



測定箇所 歩道部B (既設部)

測定器No No. 1 H=1500

測定日 R1. 7. 30

測定時間	暑さ指数		気温 (°C)	黒球温度 (°C)	湿球温度 (°C)	露点 (°C)	相対湿度 (%)	H=1000との差		
	WBGT IN (°C)	WBGT OUT (°C)						WBGT OUT (°C)	気温 (°C)	相対湿度 (°C)
17:00	26.4	26.2	29.0	30.5	24.6	22.7	69.0	-0.5	-0.8	0.7
17:30	26.6	26.4	27.9	29.4	25.4	24.4	81.3	0.0	-0.5	3.6
18:00	27.3	27.2	29.4	30.6	25.9	24.6	75.4	-0.1	-0.3	0.3
18:30	27.6	27.4	29.4	30.5	26.3	25.1	77.7	-0.2	-0.2	-0.1
19:00	26.8	26.7	28.6	29.3	25.7	24.6	79.0	-0.2	-0.4	0.5
19:30	26.3	26.3	28.0	28.7	25.3	24.3	80.3	-0.3	-0.6	1.0
20:00	26.1	26.1	28.0	28.5	25.1	24.0	79.0	-0.3	-0.5	0.6
20:30	26.0	26.0	27.9	28.5	25.0	23.9	78.8	-0.3	-0.5	0.7
21:00	25.9	25.9	27.7	28.1	25.0	23.9	79.7	-0.1	-0.4	0.7
21:30	25.8	25.7	27.3	27.8	24.9	23.9	81.9	-0.3	-0.5	0.3
22:00	26.0	26.0	27.8	28.4	25.0	23.9	79.5	-0.3	-0.6	0.9
22:30	26.2	26.2	28.1	28.6	25.2	24.1	79.0	-0.2	-0.4	0.8
23:00	26.0	25.9	27.6	28.0	25.1	24.1	81.2	-0.2	-0.4	0.6
23:30	25.9	25.8	27.4	27.9	25.0	24.0	81.7	-0.2	-0.5	0.9
00:00	25.9	25.9	27.3	27.8	25.1	24.2	83.0	-0.2	-0.5	0.6
00:30	25.7	25.7	27.3	27.7	24.9	24.0	82.3	-0.3	-0.5	0.6
01:00	25.7	25.6	27.0	27.2	25.0	24.2	84.7	-0.2	-0.4	1.0
01:30	25.3	25.3	26.3	26.6	24.8	24.2	88.5	-0.3	-0.5	1.2
02:00	25.2	25.2	26.1	26.5	24.7	24.2	89.5	-0.3	-0.4	0.8
02:30	25.1	25.1	25.9	26.4	24.6	24.1	89.9	-0.2	-0.4	0.7
03:00	25.2	25.2	25.9	26.7	24.6	24.1	89.8	-0.2	-0.4	0.9
03:30	25.4	25.3	26.2	27.1	24.6	24.0	87.7	-0.3	-0.5	0.8
04:00	25.6	25.5	26.6	27.2	24.9	24.2	86.7	-0.3	-0.5	1.1
04:30	25.2	25.2	26.1	26.5	24.7	24.1	88.8	-0.1	-0.4	0.8
05:00	25.0	25.0	25.9	26.1	24.6	24.1	90.0	-0.3	-0.4	1.1
05:30	25.0	24.9	25.6	26.4	24.4	24.0	90.7	-0.3	-0.5	1.1
06:00	25.7	25.5	26.1	28.4	24.6	24.0	88.0	-0.1	-0.4	1.0
06:30	27.7	27.1	28.4	34.5	24.8	23.4	74.6	-0.6	-0.8	1.0
07:00	30.0	29.2	31.3	40.2	25.7	23.4	62.8	-0.4	-0.7	1.2
平均		25.98	27.45			平均	82.09	-0.25	-0.48	0.88

高さによる差分(平均値)					高さによる平均値			
		H=1500	H=1000	H=500	H=1500	H=1000	H=500	平均値
既設部	WBGT (°C)	-0.25	-0.40		25.98	26.23	26.63	26.28
	気温 (°C)	-0.48	-0.15		27.45	27.93	28.08	27.82
	湿度 (%)	0.88	-2.49		82.09	81.21	83.70	82.33
施工部	WBGT (°C)	-0.40	0.14		26.10	26.51	26.37	26.33
	気温 (°C)	-0.38	-0.09		27.39	27.77	27.86	27.67
	湿度 (%)	-1.58	2.34		84.09	85.67	83.33	84.36

測定箇所 歩道部B (既設部)

測定器No No. 2 H=1000

測定日 R1. 7. 30

測定時間	暑さ指数		気温 (°C)	黒球温度 (°C)	湿球温度 (°C)	露点 (°C)	相対湿度 (%)	H=500との差		
	WBGT IN (°C)	WBGT OUT (°C)						WBGT OUT (°C)	気温 (°C)	相対湿度 (°C)
17:00	26.8	26.7	29.8	30.6	25.2	23.3	68.3	-0.3	0.1	-2.5
17:30	26.5	26.4	28.4	29.3	25.3	24.1	77.7	-0.6	-0.1	-5.8
18:00	27.4	27.3	29.7	30.4	26.1	24.8	75.1	-0.3	0.0	-2.6
18:30	27.6	27.6	29.6	30.2	26.5	25.3	77.8	-0.4	-0.2	-2.8
19:00	27.0	26.9	29.0	29.2	26.0	24.9	78.5	-0.5	-0.2	-2.6
19:30	26.6	26.6	28.6	28.5	25.8	24.7	79.3	-0.4	-0.1	-2.4
20:00	26.4	26.4	28.5	28.4	25.5	24.4	78.4	-0.4	-0.2	-2.0
20:30	26.3	26.3	28.4	28.4	25.4	24.2	78.1	-0.2	0.0	-2.1
21:00	26.0	26.0	28.1	28.0	25.2	24.1	79.0	-0.5	-0.2	-2.5
21:30	26.0	26.0	27.8	27.7	25.3	24.4	81.6	-0.3	-0.1	-2.3
22:00	26.2	26.3	28.4	28.2	25.4	24.3	78.6	-0.3	0.1	-3.2
22:30	26.4	26.4	28.5	28.4	25.5	24.3	78.2	-0.4	-0.1	-2.5
23:00	26.1	26.1	28.0	27.9	25.3	24.3	80.6	-0.4	-0.1	-2.6
23:30	26.0	26.0	27.9	27.7	25.3	24.3	80.8	-0.4	-0.2	-2.3
00:00	26.1	26.1	27.8	27.6	25.4	24.5	82.4	-0.4	-0.1	-2.4
00:30	26.0	26.0	27.8	27.5	25.3	24.4	81.7	-0.4	-0.1	-2.6
01:00	25.8	25.8	27.4	27.1	25.2	24.4	83.7	-0.6	-0.3	-2.7
01:30	25.5	25.6	26.8	26.5	25.1	24.5	87.3	-0.4	-0.2	-2.0
02:00	25.5	25.5	26.5	26.3	25.1	24.5	88.7	-0.3	-0.2	-2.1
02:30	25.3	25.3	26.3	26.2	24.9	24.4	89.2	-0.4	-0.2	-2.1
03:00	25.4	25.4	26.3	26.5	24.9	24.3	88.9	-0.3	-0.1	-2.4
03:30	25.6	25.6	26.7	26.9	25.0	24.3	86.9	-0.3	-0.1	-2.6
04:00	25.7	25.8	27.1	27.0	25.2	24.5	85.6	-0.3	-0.1	-2.2
04:30	25.3	25.3	26.5	26.3	24.9	24.3	88.0	-0.5	-0.2	-2.5
05:00	25.2	25.3	26.3	26.0	24.9	24.3	88.9	-0.3	-0.2	-2.2
05:30	25.2	25.2	26.1	26.3	24.8	24.3	89.6	-0.3	-0.1	-2.3
06:00	25.8	25.6	26.5	28.0	24.8	24.2	87.0	-0.4	-0.2	-2.5
06:30	28.3	27.7	29.2	34.7	25.5	24.0	73.6	-0.5	-0.4	-1.3
07:00	30.4	29.6	32.0	40.6	26.1	23.7	61.6	-0.7	-0.6	-2.1
平均	26.23	27.93				平均	81.21	-0.40	-0.15	-2.49

測定箇所 歩道部B (既設部)

測定器No No. 3 H=500

測定日 R1. 7. 30

測定時間	暑さ指数		気温 (°C)	黒球温度 (°C)	湿球温度 (°C)	露点 (°C)	相対湿度 (%)
	WBGT IN (°C)	WBGT OUT (°C)					
17:00	27.1	27.0	29.7	30.8	25.5	23.8	70.8
17:30	27.1	27.0	28.5	29.1	26.2	25.4	83.5
18:00	27.7	27.6	29.7	30.4	26.5	25.4	77.7
18:30	28.1	28.0	29.8	30.4	27.1	26.1	80.6
19:00	27.4	27.4	29.2	29.3	26.6	25.6	81.1
19:30	27.0	27.0	28.7	28.7	26.2	25.3	81.7
20:00	26.8	26.8	28.7	28.6	26.0	25.0	80.4
20:30	26.5	26.5	28.4	28.5	25.7	24.7	80.2
21:00	26.5	26.5	28.3	28.1	25.8	24.8	81.5
21:30	26.3	26.3	27.9	27.8	25.7	24.9	83.9
22:00	26.6	26.6	28.3	28.4	25.8	24.9	81.8
22:30	26.8	26.8	28.6	28.6	26.0	25.0	80.7
23:00	26.5	26.5	28.1	28.0	25.8	25.0	83.2
23:30	26.4	26.4	28.1	27.9	25.8	25.0	83.1
00:00	26.4	26.5	27.9	27.7	25.9	25.1	84.8
00:30	26.4	26.4	27.9	27.7	25.8	25.0	84.3
01:00	26.3	26.4	27.7	27.3	25.9	25.2	86.4
01:30	25.9	26.0	27.0	26.7	25.6	25.1	89.3
02:00	25.8	25.8	26.7	26.5	25.5	25.1	90.8
02:30	25.7	25.7	26.5	26.4	25.4	25.0	91.3
03:00	25.7	25.7	26.4	26.6	25.3	24.9	91.3
03:30	25.9	25.9	26.8	27.0	25.4	24.9	89.5
04:00	26.1	26.1	27.2	27.2	25.6	25.0	87.8
04:30	25.8	25.8	26.7	26.5	25.5	25.0	90.5
05:00	25.5	25.6	26.5	26.1	25.3	24.9	91.1
05:30	25.6	25.5	26.2	26.4	25.2	24.8	91.9
06:00	26.1	26.0	26.7	27.9	25.3	24.8	89.5
06:30	28.7	28.2	29.6	35.1	26.0	24.7	74.9
07:00	31.1	30.3	32.6	40.8	26.9	24.8	63.7
平均	26.63	28.08				平均	83.70

測定箇所 歩道部B (施工部)

測定器No No. 4 H=1500

測定日 R1. 7. 30

測定時間	暑さ指数		気温 (°C)	黒球温度 (°C)	湿球温度 (°C)	露点 (°C)	相対湿度 (%)	H=1000との差		
	WBGT IN (°C)	WBGT OUT (°C)						WBGT OUT (°C)	気温 (°C)	相対湿度 (°C)
17:00	26.6	26.5	29.3	30.5	25.0	23.2	69.7	-0.6	-0.7	-0.7
17:30	26.6	26.4	27.8	29.8	25.2	24.2	80.7	-0.4	-0.5	-0.7
18:00	27.4	27.2	28.8	30.8	25.9	24.8	79.1	-0.6	-0.5	-1.4
18:30	27.8	27.7	29.6	30.8	26.5	25.3	77.9	-0.3	-0.4	-0.8
19:00	27.1	27.0	28.7	29.4	26.1	25.1	80.7	-0.4	-0.4	-1.2
19:30	26.6	26.5	28.1	28.6	25.7	24.8	82.3	-0.4	-0.4	-1.3
20:00	26.4	26.4	28.1	28.5	25.5	24.5	80.9	-0.3	-0.3	-1.4
20:30	26.3	26.2	28.0	28.5	25.3	24.2	79.9	-0.4	-0.4	-1.4
21:00	26.0	25.9	27.6	28.0	25.1	24.2	82.0	-0.4	-0.3	-1.5
21:30	25.9	25.9	27.3	27.7	25.2	24.4	84.0	-0.4	-0.4	-1.4
22:00	26.2	26.2	27.8	28.4	25.3	24.3	81.1	-0.3	-0.4	-1.4
22:30	26.3	26.3	28.0	28.5	25.4	24.4	80.9	-0.3	-0.3	-1.6
23:00	26.2	26.1	27.6	28.0	25.4	24.5	83.1	-0.4	-0.3	-1.9
23:30	26.0	25.9	27.4	27.8	25.2	24.4	83.7	-0.4	-0.3	-1.7
00:00	25.9	25.9	27.2	27.7	25.2	24.4	84.8	-0.4	-0.4	-1.7
00:30	25.9	25.9	27.3	27.5	25.2	24.4	84.1	-0.3	-0.3	-1.8
01:00	25.7	25.7	26.7	26.8	25.2	24.6	88.4	-0.4	-0.3	-1.8
01:30	25.4	25.4	26.1	26.4	25.0	24.6	91.4	-0.4	-0.4	-1.9
02:00	25.3	25.3	26.0	26.3	24.9	24.5	91.6	-0.5	-0.4	-1.9
02:30	25.2	25.2	25.8	26.1	24.8	24.4	92.2	-0.4	-0.4	-1.7
03:00	25.3	25.2	25.8	26.5	24.8	24.4	91.8	-0.4	-0.3	-1.9
03:30	25.5	25.4	26.2	26.9	24.9	24.4	89.8	-0.4	-0.3	-2.4
04:00	25.6	25.5	26.4	27.0	25.0	24.5	89.3	-0.4	-0.3	-1.8
04:30	25.3	25.3	26.0	26.3	24.9	24.5	91.2	-0.4	-0.4	-1.6
05:00	25.1	25.0	25.6	25.9	24.7	24.3	92.4	-0.5	-0.4	-2.0
05:30	25.2	25.1	25.6	26.2	24.7	24.4	93.0	-0.3	-0.3	-2.0
06:00	25.7	25.5	26.0	27.9	24.7	24.2	90.1	-0.4	-0.3	-1.9
06:30	27.7	27.1	28.1	34.3	24.9	23.6	76.8	-0.6	-0.7	-0.4
07:00	30.1	29.3	31.4	39.2	26.2	24.2	65.8	-0.3	-0.1	-2.6
平均		26.10	27.39			平均	84.09	-0.40	-0.38	-1.58

測定箇所 歩道部B (施工部)

測定器No No. 5 H=1000

測定日 R1. 7. 30

測定時間	暑さ指数		気温 (°C)	黒球温度 (°C)	湿球温度 (°C)	露点 (°C)	相対湿度 (%)	H=500との差		
	WBGT IN (°C)	WBGT OUT (°C)						WBGT OUT (°C)	気温 (°C)	相対湿度 (°C)
17:00	27.2	27.1	30.0	30.6	25.7	24.0	70.4	0.0	-0.1	2.2
17:30	27.0	26.8	28.3	29.8	25.8	24.8	81.4	-0.2	-0.2	0.1
18:00	28.0	27.8	29.3	31.4	26.6	25.6	80.5	0.0	-0.1	0.7
18:30	28.0	28.0	30.0	30.5	27.0	25.9	78.7	0.2	0.1	1.3
19:00	27.4	27.4	29.1	29.2	26.6	25.7	81.9	0.1	-0.2	2.6
19:30	26.9	26.9	28.5	28.4	26.2	25.4	83.6	0.1	-0.1	2.5
20:00	26.7	26.7	28.4	28.4	26.0	25.1	82.3	0.1	-0.2	2.3
20:30	26.6	26.6	28.4	28.3	25.9	24.9	81.3	0.0	-0.2	2.0
21:00	26.3	26.3	27.9	27.9	25.6	24.8	83.5	0.1	-0.1	2.2
21:30	26.3	26.3	27.7	27.6	25.7	25.0	85.4	0.1	-0.1	2.5
22:00	26.5	26.5	28.2	28.2	25.8	24.9	82.5	0.2	0.0	2.2
22:30	26.6	26.6	28.3	28.3	25.9	25.0	82.5	0.2	0.0	1.9
23:00	26.5	26.5	27.9	27.8	25.9	25.1	85.0	0.1	-0.1	2.3
23:30	26.3	26.3	27.7	27.6	25.7	25.0	85.4	0.1	-0.1	2.2
00:00	26.3	26.3	27.6	27.5	25.8	25.1	86.5	0.1	-0.1	2.3
00:30	26.2	26.2	27.6	27.3	25.7	25.0	85.9	0.2	0.0	2.0
01:00	26.0	26.1	27.0	26.6	25.8	25.3	90.2	0.3	0.0	2.3
01:30	25.8	25.8	26.5	26.1	25.6	25.3	93.3	0.2	0.0	2.8
02:00	25.8	25.8	26.4	26.1	25.6	25.3	93.5	0.3	0.0	2.9
02:30	25.6	25.6	26.2	26.0	25.4	25.1	93.9	0.3	0.0	2.8
03:00	25.6	25.6	26.1	26.3	25.3	25.0	93.7	0.2	-0.1	3.0
03:30	25.8	25.8	26.5	26.6	25.5	25.1	92.2	0.2	0.0	2.5
04:00	25.9	25.9	26.7	26.7	25.5	25.1	91.1	0.2	-0.1	2.6
04:30	25.7	25.7	26.4	26.1	25.5	25.1	92.8	0.2	0.0	2.5
05:00	25.4	25.5	26.0	25.7	25.3	25.0	94.4	0.3	0.0	2.9
05:30	25.4	25.4	25.9	26.0	25.2	25.0	95.0	0.2	0.0	3.2
06:00	26.0	25.9	26.3	27.6	25.3	24.9	92.0	0.2	-0.1	3.2
06:30	28.2	27.7	28.8	34.3	25.6	24.4	77.2	-0.1	-0.5	2.9
07:00	30.3	29.6	31.5	38.4	26.8	25.0	68.4	0.2	-0.4	2.9
平均		26.51	27.77			平均	85.67	0.14	-0.09	2.34

測定箇所 歩道部B (施工部)

測定器No No. 6 H=500

測定日 R1. 7. 30

測定時間	暑さ指数		気温 (°C)	黒球温度 (°C)	湿球温度 (°C)	露点 (°C)	相対湿度 (%)
	WBGT IN (°C)	WBGT OUT (°C)					
17:00	27.2	27.1	30.1	31.1	25.5	23.6	68.2
17:30	27.1	27.0	28.5	29.9	25.9	25.0	81.3
18:00	28.0	27.8	29.4	31.6	26.5	25.5	79.8
18:30	27.8	27.8	29.9	30.4	26.7	25.5	77.4
19:00	27.3	27.3	29.3	29.3	26.4	25.3	79.3
19:30	26.8	26.8	28.6	28.5	26.0	25.0	81.1
20:00	26.6	26.6	28.6	28.5	25.8	24.8	80.0
20:30	26.6	26.6	28.6	28.3	25.8	24.7	79.3
21:00	26.2	26.2	28.0	28.0	25.5	24.5	81.3
21:30	26.1	26.2	27.8	27.6	25.5	24.6	82.9
22:00	26.3	26.3	28.2	28.2	25.5	24.5	80.3
22:30	26.4	26.4	28.3	28.3	25.6	24.6	80.6
23:00	26.3	26.4	28.0	27.8	25.7	24.8	82.7
23:30	26.1	26.2	27.8	27.6	25.5	24.7	83.2
00:00	26.2	26.2	27.7	27.5	25.6	24.8	84.2
00:30	26.0	26.0	27.6	27.3	25.4	24.6	83.9
01:00	25.8	25.8	27.0	26.6	25.4	24.8	87.9
01:30	25.6	25.6	26.5	26.2	25.3	24.8	90.5
02:00	25.5	25.5	26.4	26.1	25.2	24.7	90.6
02:30	25.3	25.3	26.2	26.0	25.0	24.6	91.1
03:00	25.4	25.4	26.2	26.3	25.0	24.6	90.7
03:30	25.6	25.6	26.5	26.7	25.2	24.7	89.7
04:00	25.7	25.7	26.8	26.7	25.3	24.7	88.5
04:30	25.5	25.5	26.4	26.1	25.2	24.7	90.3
05:00	25.1	25.2	26.0	25.7	24.9	24.5	91.5
05:30	25.3	25.2	25.9	26.1	24.9	24.5	91.8
06:00	25.8	25.7	26.4	27.7	25.0	24.4	88.8
06:30	28.4	27.8	29.3	34.8	25.6	24.2	74.3
07:00	30.1	29.4	31.9	38.2	26.6	24.6	65.5
平均	26.37	27.86				平均	83.33

項目番号	1	測定箇所	歩道部B	(既設部)
製造番号	180533285	測定器No	No. 1-上	H=1000
機種コメント	LR5041	測定日時	R1. 7. 30	
CHコメント	CH1			
属性	瞬時値			
単位	mV			
平均	7.26			
最大	14.25			
最小	0			
積算	188.7			

測定時間	測定値 (mV)	計算値および固有値			
		電圧	感度	日射量	アルベド値
		U (μ v)	S (μ v/(W/m ²))	Eu (W/m ²)	EI/Eu
17:00	1.45	1450	14.86	98	0.112
17:30	1.42	1420	14.86	96	0.125
18:00	0.62	620	14.86	42	0.190
18:30	0.18	180	14.86	12	0.250
19:00	-0.03	-30	14.86	-2	-0.500
19:30	-0.07	-70	14.86	-5	-0.200
20:00	-0.05	-50	14.86	-3	-0.667
20:30	-0.05	-50	14.86	-3	-0.333
21:00	-0.05	-50	14.86	-3	-0.333
21:30	-0.04	-40	14.86	-3	-0.333
22:00	-0.03	-30	14.86	-2	-0.500
22:30	-0.03	-30	14.86	-2	-0.500
23:00	-0.05	-50	14.86	-3	-0.333
23:30	-0.05	-50	14.86	-3	-0.333
00:00	-0.04	-40	14.86	-3	-0.333
00:30	-0.05	-50	14.86	-3	-0.333
01:00	-0.06	-60	14.86	-4	-0.250
01:30	-0.06	-60	14.86	-4	-0.250
02:00	-0.04	-40	14.86	-3	-0.333
02:30	-0.04	-40	14.86	-3	-0.333
03:00	-0.02	-20	14.86	-1	-1.000
03:30	-0.02	-20	14.86	-1	-1.000
04:00	-0.03	-30	14.86	-2	-0.500
04:30	-0.06	-60	14.86	-4	-0.250
05:00	-0.01	-10	14.86	-1	-1.000
05:30	0.30	300	14.86	20	0.200
06:00	1.42	1420	14.86	96	0.156
06:30	2.95	2950	14.86	199	0.121
07:00	4.46	4460	14.86	300	0.103

平均値

-0.331

項目番号	1	測定箇所	歩道部B	(既設部)
製造番号	180533284	測定器No	No. 1-下	H=1000
機種コメント	LR5041	測定日時	R1. 7. 30	
CHコメント	CH1			
属性	瞬時値			
単位	mV			
平均	0.94			
最大	1.82			
最小	0.04			
積算	24.41			

測定時間	測定値 (mV)	計算値および固有値		
		電圧	感度	日射量
		U (μV)	S (μV/(W/m ²))	EI (W/m ²)
17:00	0.17	170	15.00	11
17:30	0.18	180	15.00	12
18:00	0.12	120	15.00	8
18:30	0.05	50	15.00	3
19:00	0.02	20	15.00	1
19:30	0.02	20	15.00	1
20:00	0.03	30	15.00	2
20:30	0.02	20	15.00	1
21:00	0.02	20	15.00	1
21:30	0.02	20	15.00	1
22:00	0.02	20	15.00	1
22:30	0.02	20	15.00	1
23:00	0.01	10	15.00	1
23:30	0.02	20	15.00	1
00:00	0.02	20	15.00	1
00:30	0.02	20	15.00	1
01:00	0.02	20	15.00	1
01:30	0.01	10	15.00	1
02:00	0.02	20	15.00	1
02:30	0.02	20	15.00	1
03:00	0.02	20	15.00	1
03:30	0.01	10	15.00	1
04:00	0.02	20	15.00	1
04:30	0.01	10	15.00	1
05:00	0.02	20	15.00	1
05:30	0.06	60	15.00	4
06:00	0.22	220	15.00	15
06:30	0.36	360	15.00	24
07:00	0.47	470	15.00	31

項目番号	3	測定箇所	歩道部B	(施工部)
製造番号	180533286	測定器No	No. 2-上	H=1000
機種コメント	LR5041	測定日時	R1. 7. 30	
CHコメント	CH1			
属性	瞬時値			
単位	mV			
平均	8.36			
最大	15.41			
最小	0.01			
積算	217.36			

測定時間	測定値 (mV)	計算値および固有値			
		電圧	感度	日射量	アルベド値
		U (μ v)	S (μ v/(W/m ²))	Eu (W/m ²)	EI/Eu
17:00	1.50	1500	15.78	95	0.326
17:30	1.56	1560	15.78	99	0.313
18:00	0.99	990	15.78	63	0.333
18:30	0.21	210	15.78	13	0.462
19:00	-0.04	-40	15.78	-3	-0.333
19:30	-0.06	-60	15.78	-4	-0.250
20:00	-0.04	-40	15.78	-3	-0.333
20:30	-0.05	-50	15.78	-3	-0.333
21:00	-0.04	-40	15.78	-3	-0.333
21:30	-0.04	-40	15.78	-3	-0.333
22:00	-0.02	-20	15.78	-1	-1.000
22:30	-0.03	-30	15.78	-2	-0.500
23:00	-0.04	-40	15.78	-3	-0.333
23:30	-0.04	-40	15.78	-3	-0.333
00:00	-0.04	-40	15.78	-3	-0.333
00:30	-0.05	-50	15.78	-3	-0.333
01:00	-0.04	-40	15.78	-3	-0.333
01:30	-0.05	-50	15.78	-3	-0.333
02:00	-0.04	-40	15.78	-3	-0.333
02:30	-0.03	-30	15.78	-2	-0.500
03:00	-0.01	-10	15.78	-1	-1.000
03:30	-0.02	-20	15.78	-1	-1.000
04:00	-0.02	-20	15.78	-1	-1.000
04:30	-0.05	-50	15.78	-3	-0.333
05:00	0.01	10	15.78	1	2.000
05:30	0.43	430	15.78	27	0.407
06:00	1.61	1610	15.78	102	0.304
06:30	3.21	3210	15.78	203	0.345
07:00	4.82	4820	15.78	305	0.325

平均値	-0.399
-----	--------

項目番号	1	測定箇所	歩道部B	(施工部)
製造番号	180533283	測定器No	No. 2-下	H=1000
機種コメント	LR5041	測定日時	R1. 7. 30	
CHコメント	CH1			
属性	瞬時値			
単位	mV			
平均	3.29			
最大	6.03			
最小	0.05			
積算	85.57			

測定時間	測定値 (mV)	計算値および固有値		
		電圧	感度	日射量
		U (μV)	S (μV/(W/m ²))	E (W/m ²)
17:00	0.52	520	16.68	31
17:30	0.52	520	16.68	31
18:00	0.35	350	16.68	21
18:30	0.10	100	16.68	6
19:00	0.01	10	16.68	1
19:30	0.01	10	16.68	1
20:00	0.02	20	16.68	1
20:30	0.02	20	16.68	1
21:00	0.02	20	16.68	1
21:30	0.02	20	16.68	1
22:00	0.02	20	16.68	1
22:30	0.01	10	16.68	1
23:00	0.01	10	16.68	1
23:30	0.01	10	16.68	1
00:00	0.01	10	16.68	1
00:30	0.01	10	16.68	1
01:00	0.02	20	16.68	1
01:30	0.02	20	16.68	1
02:00	0.02	20	16.68	1
02:30	0.01	10	16.68	1
03:00	0.01	10	16.68	1
03:30	0.01	10	16.68	1
04:00	0.01	10	16.68	1
04:30	0.01	10	16.68	1
05:00	0.04	40	16.68	2
05:30	0.18	180	16.68	11
06:00	0.51	510	16.68	31
06:30	1.16	1160	16.68	70
07:00	1.65	1650	16.68	99










































風速計測結果および赤外線撮影記録





















































歩道部A シートNo. 11






























































測定箇所：歩道部 B(既設部, 施工部)







































測定器No.: TVS-500

測定日：R1.7.30

測定時間	風速 (m/s)	路面温度(赤外線サーモグラフィによる測定)										備考		
		No. 1 既設 Data. No	No. 2 境界部 Data. No	No. 3 対策済 Data. No	No. 1 既設部 路面温度(℃)		No. 2 境界部 路面温度(℃)		No. 3 施工部 路面温度(℃)		温度差 (℃)			
17:00	3.6	248, 249	246, 247	243, 244	 42.3	 37.7	 42.3	 39.1	 42.2	 38.8	38.0			
17:30	1.8	251, 252	253	254, 255	 37.4	 33.4	 35.7	 33.2	-	 33.7	 33.0	3.7		
18:00	0.3	256, 257	259, 260	261, 262	 38.5	 37.1	 37.3	 33.7	 37.0	 32.5	33.7	33.9	4.8	
18:30	0.2	264, 265	267, 268	269, 270	 38.0	 36.8	 37.1	 33.7	 36.9	 33.4	33.0	33.0	5.0	
19:00	0.9	272, 273	275, 276	277, 278	 37.4	 36.6	 36.0	 33.0	 36.1	 32.9	32.9	32.5	4.5	
19:30	0.5	2, 3	4	5, 6	 36.5	 35.8	 35.0	 32.0	-	 32.4	 31.9	4.1		
20:00	0.3	7, 8	10, 11	12, 13	 36.0	 35.0	 34.0	 31.2	 34.5	 33.4	32.0	31.5	4.0	

測定 時間	風速 (m/s)	路面温度(赤外線サーモグラフィによる測定)										備考		
		No. 1 既設 Data. No	No. 2 境界部 Data. No	No. 3 対策済 Data. No	No. 1 既設部 路面温度(℃)		No. 2 境界部 路面温度(℃)		No. 3 施工部 路面温度(℃)		温度差 (℃)			
20:30	0.4	15, 16	18, 19	20, 21	 35.5	 35.0	 34.7	 31.9	 34.5	 31.4	 31.5	 31.0	4.0	
21:00	0.5	23, 24	25	26, 27	 35.2	 34.5	 34.0	 31.4	-		 31.0	 31.2	4.2	
21:30	0.3	1, 2	3	4, 5	 34.7	 34.4	 33.2	 30.5	-		 30.7	 30.9	4.0	
22:00	0.3	6, 7	9, 10	11, 12	 34.8	 34.5	 33.5	 31.7	 34.0	 32.2	 31.5	 31.4	3.3	
22:30	0.2	14, 15	17, 18	19, 20	 34.8	 34.2	 33.5	 31.4	 33.5	 33.0	 31.4	 31.5	3.4	
23:00	0.4	22, 23	25, 26	27, 28	 34.2	 33.4	 32.5	 30.7	 32.5	 30.4	 30.2	 30.0	4.0	
23:30	0.2	30, 31	33, 34	35, 36	 33.5	 31.0	 32.4	 30.2	 32.4	 30.0	 30.4	 30.0	3.1	
0:00	0.4	38, 39	41, 42	43, 44	 33.5	 33.0	 32.0	 30.2	 32.2	 31.5	 30.0	 29.7	3.5	

測定 時間	風速 (m/s)	路面温度(赤外線サーモグラフィによる測定)										備 考		
		No. 1 既設 Data. No	No. 2 境界部 Data. No	No. 3 対策済 Data. No	No. 1 既設部 路面温度(°C)		No. 2 境界部 路面温度(°C)		No. 3 施工部 路面温度(°C)		温度差 (°C)			
0:30	0.0	1, 2	4, 5	6, 7	 33.0	 32.7	 31.9	 29.5	 31.9	 30.0	 29.7	 29.5	3.3	
1:00	0.0	9, 10	12, 13	14, 15	 32.7	 32.7	 31.9	 29.7	 31.9	 31.2	 29.3	 29.5	3.4	
1:30	0.0	17, 18	20, 21	22, 23	 32.5	 32.4	 31.2	 29.5	 30.7	 29.9	 29.2	 29.0	3.3	
2:00	0.0	25, 26	28, 29	30, 31	 32.5	 31.7	 31.9	 29.0	 31.0	 28.8	 29.0	 28.5	3.5	
2:30	0.0	33, 34	36, 37	38, 39	 32.2	 31.9	 31.0	 29.2	 31.2	 29.2	 28.8	 28.5	3.4	
3:00	0.0	41, 42	44, 45	46, 47	 32.7	 32.5	 31.5	 30.4	 31.7	 29.0	 30.0	 30.2	2.7	
3:30	0.0	49, 50	52, 53	54, 55	 32.5	 32.2	 32.0	 30.7	 31.9	 29.3	 29.9	 30.2	2.6	
4:00	0.0	1, 2	4, 5	6, 7	 32.4	 32.7	 31.5	 30.4	 31.4	 29.2	 30.2	 29.9	2.2	

測定 時間	風速 (m/s)	路面温度(赤外線サーモグラフィによる測定)										備 考		
		No. 1 既設 Data. No	No. 2 境界部 Data. No	No. 3 対策済 Data. No	No. 1 既設部 路面温度(℃)		No. 2 境界部 路面温度(℃)		No. 3 施工部 路面温度(℃)		温度差 (℃)			
4:30	0.0	9, 10	12, 13	14, 15	 32.0	 31.9	 30.4	 29.3	 30.9	 28.8	 28.5	 28.6	3.5	
5:00	0.0	17, 18	20, 21	22, 23	 31.4	 32.0	 30.4	 28.8	 30.9	 28.8	 28.3	 28.3	3.1	
5:30	0.0	25, 26	28, 29	30, 31	 31.7	 31.4	 30.4	 28.3	 30.2	 28.5	 28.5	 28.3	3.2	
6:00	0.0	33, 34	36, 37	38, 39	 32.0	 32.0	 30.7	 28.6	 31.0	 29.7	 28.8	 28.8	3.2	
6:30	0.0	41, 42	44, 45	46, 47	 33.7	 35.8	 32.4	 29.3	 33.0	 30.2	 30.2	 29.9	3.5	
7:00	0.0	49, 50	52, 53	54, 55	 36.8	 38.2	 35.3	 31.9	 35.5	 31.7	 31.7	 31.4	5.1	
平均温度					34.5						30.9		3.6	